

# 2007 Annual Drinking Water Quality Report

(Consumer Confidence Report)

for

## Emerald Bay Municipal Utility District

Phone Number: (903) 825-6960

***Special Notice for the ELDERLY, INFANTS, CANCER PATIENTS, people with HIV/AIDS or other immune problems:***

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The EPA/Centers for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

---

### Public Participation Opportunities

The District Board of Directors holds regularly scheduled monthly board meetings on the 2<sup>nd</sup> Monday of each month at 05:30 PM at the Emerald Bay Club House, 203 South Bay Drive, Bullard, TX 75757

If you have a particular question regarding your drinking water please call us at: **(903) 825-6960**. All calls are returned.

***Our Drinking Water Meets or Exceeds  
All Federal (EPA) Drinking Water Requirements***

This report is a summary of the quality of water we provide to our customers. The analysis was made by using the data from the most recent U.S. Environmental Protection Agency (EPA) required test and is presented in the attached pages. We hope this information helps you become more knowledgeable about what's in your drinking water.

---

***Water Sources:*** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals, and in some cases, radioactive materials, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water before treatment include: microbes, inorganic contaminants, pesticides, herbicides, radioactive contaminants, and organic chemical contaminants.

## ***En Español***

Este informe incluye información importante sobre el agua potable. Si tiene preguntas o comentarios sobre este informe en español, favor de llamar al tel. (903) 825-6960 – Para hablar con una persona bilingue en español.

### ***Where do we get our drinking water?***

Our drinking water comes from the **Carrizo/Wilcox Aquifer**. A Source Water Susceptibility Assessment is being updated by the Texas Commission on Environmental Quality and will be provided to us this year. The report will describe the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information contained in the assessment will allow us to focus on our source water protection strategies. For more information on source water assessments and protection efforts at our system, please contact us.

### ***All drinking water may contain contaminants.***

When drinking water meets federal standards there may not be any health based benefits to purchasing bottled water or point of use devices. Drinking water, including bottled water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of some contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791).

### ***Secondary Constituents***

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water can cause taste, color, and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, and not the EPA. These constituents are not causes for health concern. Therefore, secondary's are not required to be reported in this document but may greatly affect the appearance and taste of your water.

### ***About the following pages***

The pages that follow list all the federally regulated or monitored contaminants which have been found in your drinking water. The U.S. EPA requires water systems to test up to 97 contaminants.

## **DEFINITIONS**

### **Maximum Contaminant Level (MCL)**

The highest permissible level of contaminant in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.

### **Maximum Contaminant Level Goal (MCLG)**

The level of contaminant level in drinking water below which there is no known or expected health risk. MCLG's allow for a margin of safety.

### **Maximum Residual Disinfectant Level (MRDL)**

The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)**

The level of drinking water disinfectant which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contamination.

**Treatment Technique (TT)**

A required process intended to reduce the level of contaminant in drinking water.

**Action Level**

The concentration of a contaminant which, if exceeded, triggers treatment or other requirement which a water system must follow.

**ABBREVIATIONS**

- NTU** – Nephelometric Turbidity Units
- MFL** – million fibers per liter (a measure of asbestos)
- pCi/L** – picocuries per liter (a measure of radioactivity)
- ppm** – parts per million, or milligrams per liter (mg/L)
- ppb** – parts per billion, or micrograms per liter (ug/L)
- ppg** – parts per quadrillion, or pictograms per liter

**Results of Testing****Inorganic Contaminants:**

Year	Contaminant	Average Level	Minimum Level	Maximum Level	MCL	MCLG	Unit of Measure	Source of Contaminant
2007	Barium	0.034	0.034	0.034	2	2	ppm	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
2007	Fluoride	0.24	0.24	0.24	4	4	ppm	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
2007	Combined Radium 226 & 228	0.33	0.33	0.33	5	0	pCi/L	Erosion of natural deposits.
2007	Cross Beta Emitters	3.7	3.7	3.7	50	0	pCi/L	Decay of natural and man-made deposits.

**Organic Contaminants:**

TESTING WAIVED, NOT REPORTED, OR NONE DETECTED

**Maximum Residual Disinfectant Level:**

Year	Disinfectant	Average Level	Minimum Level	Maximum Level	MRDL	MRDLG	Unit of Measure	Source of Disinfectant
2007	Chlorine Residual, Free	1.50	0.49	1.73	4	4	ppm	Chlorine Gas

### Disinfection Byproducts:

Year	Contaminant	Average Level	Minimum Level	Maximum Level	MCL	Unit of Measure	Source of Contaminant
2007	Total Trihalomethanes	9.9	9.9	9.9	80	ppb	Byproduct of drinking water disinfection

### Unregulated Initial Distribution System Evaluation for Disinfection Byproducts:

WAIVED, OR NOT YET SAMPLED

### Unregulated Contaminants:

Bromoform, chloroform, dichlorobromomethane, dibromochloromethane are disinfectant byproducts. There is no maximum contaminant level for these chemicals at the entry point to distribution.

Year	Contaminant	Average Level	Minimum Level	Maximum Level	Unit of Measure	Source of Contaminant
2007	Chloroform	2.68	2.68	2.68	ppb	Byproduct of drinking water disinfection
2007	Bromodichloromethane	2.87	2.87	2.87	ppb	Byproduct of drinking water disinfection
2007	Dibromochloromethane	2.33	2.33	2.33	ppb	Byproduct of drinking water disinfection

### Lead and Copper:

TESTING WAIVED, NOT REPORTED, OR NONE DETECTED

#### Recommended Additional Health Information for Lead

All water systems are required by the EPA to report the language below starting with the 2009 CCR to be delivered to you by July of 2010. We are providing this information now as a courtesy.

*"If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water supply is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>."*

### Turbidity:

NOT REQUIRED

### Total Coliform:

REPORTED MONTHLY TESTS FOUND **NO** COLIFORM BACTERIA

## Fecal Coliform:

REPORTED MONTHLY TESTS FOUND **NO** FECAL COLIFORM BACTERIA

## Secondary and Other Constituents Not Regulated:

Year or Range	Constituent	Average Level	Minimum Level	Maximum Level	Secondary Limit	Unit of Measure	Source of Constituent
2007	Aluminum	0.008	0.008	0.008	.050	ppm	Abundant naturally occurring element.
2007	Bicarbonate	104	104	104	NA	ppm	Corrosion of carbonate rocks such as limestone.
2007	Calcium	3	3	3	NA	ppm	Abundant naturally occurring element.
2007	Chloride	10	10	10	300	ppm	Abundant naturally occurring element; used in water purification; byproduct of oil field activity
2007	Copper	0.003	0.003	0.003	1	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives .
2007	Hardness as Ca/Mg	11	11	11	NA	ppm	Naturally occurring calcium and magnesium.
2007	Magnesium	0.8	0.8	0.8	NA	ppm	Abundant naturally occurring element.
2007	Manganese	0.0013	0.0013	0.0013	.05	ppm	Abundant naturally occurring element.
2007	pH	7.7	7.7	7.7	>7.0	units	Measure of corrosivity of water.
2007	Sodium	58	58	58	NA	ppm	Erosion of natural deposits; byproduct of oil field activity.
2007	Sulfate	13	13	13	300	ppm	Naturally occurring ; common industrial; byproduct of oil field activity.
2007	Total Alkalinity as CaCO <sub>3</sub>	104	104	104	NA	ppm	Naturally occurring soluble mineral salts.
2007	Total Dissolved Solids	142	142	142	1000	ppm	Total dissolved mineral constituents in water.
2007	Zinc	0.118	0.118	0.118	5	ppm	Moderately abundant naturally occurring element; used in the metal industry.